



Flow sensor

F2

Article no. 50272/ [Immersion depth]

Description

The calorimetric air flow sensors from SEIKOM Electronic are a precise and reliable instrument for measuring gas flows. The measuring principle is based on the calorimetric method, in which the change in temperature of the sensor element is proportional to the mass of the passing gas volume.

Due to the highly accurate measurement method, the sensor enables precise determination of the mass air flow, ensuring optimal control and regulation of industrial processes. The sensor from SEIKOM Electronic offers a robust and reliable solution for a wide range of applications where accurate monitoring of the air flow is crucial.

Installation conditions

The flow sensor must be connected to the associated evaluation unit according to the connection diagram. Mixing up the connections will lead to malfunctions and possibly to damage.

Screw in the sensor only via the hexagon of the sensor housing. The sensor is not dependent on the installation position and can therefore be mounted from all sides. The sensor tip should be as close as possible to the center of the pipe. The through hole in the shaft of the sensor must be located completely inside the duct.

There is a small indentation in the metal at the end of the sensor. This marking is intended as a mounting aid and must be placed in the direction from which the gas flow is coming.

For vertical pipes, the direction of flow should be upwards, especially for small air flows (up to 1 m/s), in order to avoid influences from thermally rising air.

For optimum measurement, the sensor requires at least 5 x D (inner pipe diameter) of the free inlet and inlet and 3 x D of the outlet to avoid incorrect measurements due to turbulence.

To avoid malfunctions, the sensor cable must be extended with a cross-section of at least 1.5 mm². The maximum cable length should not exceed 50 m.

The switching point is set via the potentiometer of the associated evaluation unit.

Various options are available for mounting the sensor:

- *Recommended:* Screw-in of the sensor by means of **screw-in adapter** (article no. 80404) to variably determine the immersion depth of the sensor and for easy cleaning of the sensor
- **Screw the sensor** into the duct or pipe using a PG7 thread (alternative connections G1/2-inch, M16 x 1.5 and M20 x 1.5 possible using a reducer).
- Mounting by means of **mounting flange** (article no. 79781/10)

Technical data

Media temperature range	-10 ... 80°C
Temperature gradient	15K/min
Immersion depth appr.	50 mm (Standard) or 35 mm
Process connection	PG7 (optionally possible by means of reducer G1/2-inch, M 16 x 1,5 or M 20 x 1,5)
Sensor material	MS58, nickel-plated, optionally stainless steel (V4A)
Compressive strength	10 bar
Protection class	IP67
Associated evaluation units	NLSW®2a NLSW®45-3 NLSW®75-A
Testmark	Type-tested TÜV Nord

Electrical data

Connection line	2,5 m / 3 x 0,5mm ²
-----------------	--------------------------------

Maintenance instructions

The flow sensor should be cleaned at regular intervals, especially when used in heavily contaminated media. The following procedure is recommended:

- Disassemble sensor
- Carefully soak the sensor in lukewarm soapy water for approx. 10 min. (depending on the contamination)
- Rinse the sensor with lukewarm water and then allow to dry for at least 24 hours
- Mount sensor in dry condition
- Start up the flow monitor and if necessary, perform a new calibration with the evaluation unit

Article number Flow sensor F2

Article No.	50272/	50
Immersion depth	50	50 mm

Dimensions

Sensor F2/50:

